

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 612-2024

Dated: 30/09/2024

It is certified that an inspection team headed by Sanil Kumar (JE)

(Name of Officers with designation) from Jal Nigam PHED

inspected the Anshu public School Dadri

(Name & Address of the school) on 30/09/24 (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. STM/2024/09/24/01

dated 27/09/24 of Supreme Tst house (PHED Lab) certified that the

Anshu public School, Dadri (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the

hygienic sanitation condition in the school building & the campus as per norms prescribed by

the Central/State/U.T. Govt. This certificate is valid till Three year from

sample date. (25-09-2027)

Sanil Kumar
अवर अभियंता
जल निगम
(गीतमबुद्धनगर)
30/09/24

Signature with Seal:


शुभम लोहा
MANAGER
ANSHU PUBLIC SCHOOL
DADRI (G.B.NAGAR)

Name : Sanil Kumar

Designation : Junior Engineer

Name & Address of the Office / Department : Jal Nigam Surajpur G.B. Nagar

Principal
PRINCIPAL
Anshu Public School
Dadri (G.B. Nagar)



SUPREME TEST HOUSE

Address: B-9, 2nd Floor, Sector 64, Noida, Gautam Budha Nagar, U.P. 201301

Mobile: +91-82658 94049 | +91-95993 42128

Website: www.supremetesthouse.com

Email: info@supremetesthouse.com



An ISO 9001:2015, ISO 14001:2015, ISO 45001:2018 Certified Laboratory


NABL ACCREDITED LABORATORY

TEST REPORT

Sample Name: Drinking Water	Report No: STH/2024/09/24/01
Customer Name: Anshu Public School	Sample Quantity: 2 Ltr.
Customer Address: Dadri Uttar Pradesh.	Sample Condition : Good
	Temperature: 25°C±2
	Humidity : 55%±10
ULR No.:- TC10581024092401F	Ref. No.:-Nil
Sample Received On: 24/09/2024	Duration of Testing: 24/09/2024-27/09/2024
Tested Location : At Laboratory	Reporting Date : 27/09/2024

S.No.	Test Parameter	Test Result	Requirement as per 15:10500:2012, Acceptable/Permissible Limit in the absence of alternate source	Test Method
Chemical Parameters				
1.)	Color, Hazen units	2	5/15	IS: 3025-(P-4)-1983
2.)	Odour	Agreeable	Agreeable/ Agreeable	IS: 3025-(P-5)-2018
3.)	pH @27°C	6.98	6.5-8.5/No relaxation	IS: 3025-(P-11)-1983
4.)	Taste	Agreeable	Agreeable/ Agreeable	IS: 3025-(P-8)-1984
5.)	Turbidity (NTU), Max.	<1	1/5	IS: 3025-(P-10)-1984
6.)	T.D.S (mg/l), Max.	40	500/2000	IS: 3025-(P-16)-1984
7.)	Total hardness (mg/l), Max.	8.4	200/600	IS: 3025-(P-21)-2009
8.)	Chloride (mg/l), Max	11	250/1000	IS: 3025-(P-32)-1988
9.)	Residual free chlorine (mg/l),Max	NIL	0.2/1	IS: 3025-(P-26)-1986
10.)	Iron (mg/l) ,Max	0.004	1.0/No Relaxation	IS: 3025-(P-53)-2003
11.)	Fluoride (mg/l) ,Max	0.008	1.0/1.5	APHA
12.)	E. Coil Bacteria	Not detected	Shall not be detectable in any 100ml Sample	IS:1622-1981
13.)	Total Coliform Bacteria	Not detected	Shall not be detectable in any 100ml Sample	IS:1622-1981


End of Report


 MANAGER
 ANSHU PUBLIC SCHOOL
 DADRI (G.B.NAGAR)

Page 1 of 1



Verified By (For Supreme Test House)


 Authorised signatory
 Pradeep Bhardwaj
 (Technical Manager)

Note: (1) The Report refers only to the particular sample(s) submitted for testing. (2) This report shall not to be reproduced except in full without approval of the laboratory or in part and cannot be evidence in the court of Law. (3) Any discrepancy observed in the test report shall be brought in to the notice of the laboratory within week. (4) Results Applied to the sample as received in the laboratory submitted by customer.

Note: (1) The report refers only to the particular sample(s) submitted for testing. (2) This report shall not to be reproduced except in full without approval of the laboratory or in part and cannot be evidence in the court of Law. (3) Any discrepancy observed in the test report shall be brought in to the notice of the laboratory within week.